

NON POTABLE WATER BACTERIOLOGICAL SAMPLE COLLECTION AND LABORATORY REPORTING FORMAT

ENVIRONMENTAL REAGENT SERVICE
3860 SW 30TH AVE FT LAUDERDALE FL 33312
CERTIFICATION NUMBER: E86563
TEL: (954) 316-8792

Lab Receipt Date & Time:	<u>12/18/18</u> <u>14:22</u>
Analysis Date & Time:	<u>12/18/18</u> <u>15:20</u>
Sample Acceptance Criteria:	
Sample Preservation	<input checked="" type="checkbox"/> On Ice <input type="checkbox"/> Not on Ice <input type="checkbox"/> 5 °C
All results meet the requirements of NELAC Standards, the results relate only to this sample	

Report Number: 31707
Analysis Requested: (please check all that apply)

Other: ENTEROCOCCI

System Name/Owner's Name: TOWN OF HIGHLAND BEACH (PWS # 450-0609)

County: PALM BEACH **Collector:** PAT ROMAN (8228)

Collector's Phone #: (561) 243-2084

Client Address: 3616 S.OCEAN BLVD

Client City: HIGHLAND BEACH **Client State:** FL

Client Zip: 33487

Sample Collection Date: 12/18/18

To be completed by lab					
Sample Number	Sample Point (Location or Station No.)	Collection Time	Enterococci Analysis Method: Enterolert		Lab Sample Number
			Enterococci CFU/100mL	Data Qualifier ²	
			Fecal Analysis Method: SM9222D 20 th ed		
			Fecal Coliform CFU/100mL	Data Qualifier ²	
1	2445 S.OCEAN BLVD.	10:30	<10	U	31707-1
2	3615 S.OCEAN BLVD.	10:40	<10	U	31707-2
3	4621 S.OCEAN BLVD.	10:50	<10	U	31707-3

Laboratory Director Signature: *Amitabh Bhatia*

<p>Name and mailing Address of Person to Receive Report</p> <p>TOWN OF HIGHLAND BEACH 3616 S. OCEAN BLVD HIGHLAND BEACH, FLORIDA 33487</p>

<input type="checkbox"/> Satisfactory <input type="checkbox"/> Incomplete Collection Information <input type="checkbox"/> Repeat Samples Required <input type="checkbox"/> Replacement Samples Required Date Reviewed by DEP/DOH: _____	DEP/DOH USE ONLY
---	-------------------------

If you have any questions, please do not hesitate to call the lab director.

DEP/DOH Reviewing Official: _____

All tests are performed in accordance with NELAC standards.
Qualifier codes (U) =not detected; (B) = result based on colony counts outside the acceptance range;
(Z) =TNTC at highest dilution performed; (Q) =sample holding time exceeding.

For enforcement samples, EPA recommends a maximum of 6 hours time lapse from sample collection to analysis of samples in the lab. Samples must be scheduled with the lab in advance to arrive by 3:30pm to Allow sufficient time for analysis. Lab procedures conform to EPA recommendations.