

TABLE 1
MAXIMUM CONTAMINANT LEVELS FOR INORGANIC COMPOUNDS

FEDERAL CONTAMINANT ID NUMBER	CONTAMINANT	MCL (mg/L)
1074	Antimony	0.006
1005	Arsenic	0.05
1094	Asbestos	7 MFL
1010	Barium	2
1075	Beryllium	0.004
1015	Cadmium	0.005
1020	Chromium	0.1
1024	Cyanide (as free Cyanide)	0.2
1025	Fluoride	4.0
1030	Lead	0.015
1035	Mercury	0.002
1036	Nickel	0.1
1040	Nitrate	10 (as N)
1041	Nitrite	1 (as N)
	Total Nitrate and Nitrite	10 (as N)
1045	Selenium	0.05
1052	Sodium	160
1085	Thallium	0.002

Abbreviations Used: MCL = maximum contaminant level;
MFL = million fibers per liter (longer than 10 micrometers);
mg/L = milligrams per liter.

TABLE 6
SECONDARY DRINKING WATER STANDARDS

FEDERAL CONTAMINANT ID NUMBER	CONTAMINANT	MCL (mg/L)*
1002	Aluminum	0.2
1017	Chloride	250
1022	Copper	1
1025	Fluoride	2.0
1028	Iron	0.3
1032	Manganese	0.05
1050	Silver	0.1
1055	Sulfate	250
1095	Zinc	5
1905	Color	15 color units
1920	Odor**	3 (threshold odor number)
1925	pH	6.5 - 8.5
1930	Total Dissolved Solids	500 (may be greater if no other maximum contaminant level is exceeded)
2905	Foaming Agents	0.5

Abbreviations Used: MCL = maximum contaminant level;
mg/L = milligrams per liter.

* Except color, odor, corrosivity, and pH.

** For purpose of compliance with ground water quality secondary standards, as referenced in Chapter 62-520, F.A.C., levels of ethylbenzene exceeding 30 micrograms per liter, toluene exceeding 40 micrograms per liter, or xylenes exceeding 20 micrograms per liter shall be considered equivalent to exceeding the drinking water secondary standard for odor.